



QUALITY CONTROL SUB DISTRICT LAB

KERALA WATER AUTHORITY

COLLECTORATE P O, KOTTAYAM

Telephone No. 0481 2302391, Email- gcsdlktm@gmail.com

TEST REPORT

Report No:156/QC/KTM/02/2024	Date:19.02.2024
------------------------------	-----------------

Customer Name & Address Thresiamma Joseph Nirmala Public School Erumely	1.Date of Receipt	14.02.2024
	2.Sampling done by	Customer
	3.Sample Code	2024/QC/KTM/M943
	4.Source of Sample	Drinking Water
	5.Sample Quantity	100ML
	6.Sample condition	Acceptable
	7.Test performing dates:15.02.2024 – 19.02.2024	

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per –IS 10500-2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	MPN METHOD	Nil
2	E.coli	Shall not be detected/100ml	MPN METHOD	Nil

Remarks: -

NB:- The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

*Samples will be retained only for 7 days after completion of analysis

*Sampling is not done by the Lab

END OF REPORT



Authorized By
[Signature]
R. Shukla



COMMUNITY HEALTH CENTRE, ERUMELY

Erumely P.O., Kottayam Dist., Kerala - 686509

Phone: 04828 210454, Fax:

email: chcerumely@gmail.com

No: 248/2024 Community Health Centre Erumely dated: 12.03.2024

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Health Inspector from CHC Erumely, Health Services Department inspected the Nirmala Public School Erumely Kottayam on 12-03-2024 and found that the Nirmala Public School Erumely has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of One year



Signature:

Name: K R Shajimon

Designation: Health Inspector

HEALTH INSPECTOR
CHC, ERUMELY

To

Nirmala Public School

Erumely, Kottayam